



Massachusetts Technology Collaborative
(Solicitation No. 2023-GA-03)
Request for Proposals for Innovation Building Roof Replacement

Questions and Answers

August 24, 2022

	QUESTION	ANSWER
1.	Is the idea to reuse as much of the existing lightning protection system as possible? Then replace anything the lightning company deems necessary, or would you like the bid to include an entirely new system with new materials?	The idea is to re-use as much as possible of what currently exists. Bids should not include an entirely new system.